

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING – BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7135-1483:176

Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Mirtone, 8985 Town Center Parkway, Bradenton, FL 34202  
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

**DESIGN:** Models MG1-P, MG1-H, MG1F-P, MG1F-HO, MG1RF-P and MG1RF-HO electronic horns; Models "EST" MG1-HD, MG1R-HD, MG1F-HD, MG1RF-HD horns with or without suffixes -R and -F. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical: 24-30 VDC  
16-33 Vdc/Vfwr – Models MG1-HD, MG1R-HD, MG1F-HD, MG1RF-HD

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as horns for use with separately listed compatible fire alarm control units. For indoor use and wall mount only. Refer to listee's Installation Instruction Manual for details.

These horns cannot generate a distinctive three-pulse temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

**FORMERLY:** 7135-1483:230

**XLF:** 7135-1657:230

09-08-05 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*